

262400S01 Switchboards and Panelboards

Panelboard Feeds:

1. The main conductor feeds to all panelboards are to be run so that all electric panels with main breakers or lugs located at the top of the panel must be fed from above and all panels with main breakers or lugs located at the bottom of the panel must be fed from below.
2. Feeders routed through the side gutters to reach the top or bottom main breakers or lugs from the opposite end of the panel are not acceptable.