

FCR 19

Office of the President
December 15, 2015

Members, Board of Trustees:

REPAIR/UPGRADE/IMPROVE BUILDING SYSTEMS –
UK HEALTHCARE CAPITAL PROJECT
(ROACH AIR HANDLING UNIT: ROACH S-1)

Recommendation: that the Board of Trustees approve the initiation of the Repair/Upgrade/Improve Building Systems – UK HealthCare Capital Project (Roach Air Handling Unit: Roach S-1).

Background: Pursuant to Administrative Regulation 8:2, any capital project with an estimated cost of \$600,000 or more must be approved by the Board prior to initiation. This project will replace the air handling unit (AHU) in the Ben F. Roach Cancer Care Facility. This AHU is 32 years old and in poor mechanical condition. It supports the 2nd floor of the building which is a clinical area. Replacement of the unit is necessary to ensure air quality, meet regulatory requirements, and to maintain the interior environment without temperature fluctuation.

The scope of this legislatively authorized project is \$1,200,000 and will be funded with agency funds.

Action taken: Approved Disapproved Other_____

